

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Stafford	Fraction N 1/2 SW 1/4 NW 1/4 NW 1/4	Section number 4	Township number T 21 S R 11 E 9	Range number
2. Distance and direction from nearest town or city: 7 mi. So., 2 1/2 mi E. of Ellinwood, Ks. Street address of well location if in city:			3. Owner of well: Ronald Rujan R.R. or street: RFD City, state, zip code: Ellinwood, Kansas 67526		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>11</u> in. Completion date _____ Well depth <u>85</u> ft. <u>3-28-78</u>
Sandy top soil			0	9	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown clay			9	17	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Soft Sandy Clay			17	38	9. Casing: Material <u>pvc</u> Height: Above or xxx Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5 1/2</u> in. to <u>85</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.258</u>
Sand & gravel			38	50	10. Screen: Manufacturer's name _____ CertainTeed Type <u>pvc</u> Dia. _____ Slot/gage xxx <u>1/32</u> Length <u>20</u> Set between <u>65</u> ft. and <u>85</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 3/4 3/8</u>
Clay			50	55	11. Static water level: _____ mo./day/yr. <u>33</u> ft. below land surface Date <u>3-28-78</u>
Clay - Sand mixes			55	70	12. Pumping level below land surfaces: <u>33</u> ft. after <u>1</u> hrs. pumping <u>40</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>100</u> g.p.m.
Good sand & gravel			70	85	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>3-28-78</u>
Clay			85		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.
					16. Nearest source of possible contamination: ft. <u>400</u> Direction <u>South</u> Type <u>septic</u> Well disinfected upon completion? <u>HTH</u> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis <u>134</u> Business name License No. Great Bend, Kansas 67530 Address Signed <u>Sandy Kilgore</u> Date <u>4-5-78</u> Authorized representative		

21 11 E 9
R
Sec
4 N 1/2 NW 1/4