


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Stafford</b>	Township name <b>Byron</b>	Fraction <b>C. NW<math>\frac{1}{4}</math></b>	Section number <b>11</b>	Town number <b>T21S</b>	Range number <b>R12W</b>
Distance and direction from nearest town or city: <b>12 mi. Northeast of Hudson, Kansas</b>				3 Owner of well: <b>Warren Rujan</b> Address: <b>Rt. 2</b> <b>Ellinwood, Kansas 67526</b>		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: <b>102</b> ft. Date of completion <b>2-18-75</b> Well diameter <b>24</b> in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
<del>XXX</del> Sandy top soil				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Sandy clay & soil				7 Casing: Material <b>Steel</b> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>16</b> in. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <b>16</b> in. to <b>16</b> in. depth Weight <b>30.3</b> lbs./ft.		
Sand & gravel				8 Screen: Manufacturer <b>Doerr</b> Type <b>Double-Slot</b> dia. <b>16"</b> Slot/gauze <b>1/8</b> Length <b>48'</b> Set between <b>49</b> and <b>69</b> Fittings: <b>74'</b> & <b>102'</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>3/8</b>		
Brown clay & gravel streaks				9 Static water level: <b>15.5</b> ft. below land surface Date <b>2-18-75</b>		
Blue clay				10 Pumping level below land surfaces: <b>N/C</b> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Sand & gravel				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Sand, gravel & fine sand				12 Well head completion: <b>XXX</b> <input type="checkbox"/> Pitless adapter <b>102</b> Inches above grade		
(use a second sheet if needed)				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.		
16 Remarks: elevation				14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Clarke Well &amp; Eq., Inc. 185</b> Business name License No. Address <b>Great Bend, KS</b> Signed <b>[Signature]</b> Date <b>2-18-75</b> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5