


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County STAFFORD	Fraction SW 1/4 NW 1/4	Section number 12	Township number T 21 S R 12 E	Range number 12 E
2. Distance and direction from nearest town or city: Stafford South of Ellinwood, Ks. to County line Street address of well Location if in city: 1 3/4 mi South-East side of road.			3. Owner of well: Sammy Jahay R.R. or street: RFD City, state, zip code: Ellinwood, Kansas 67526		
4. Locate with "X" in section below: N Sketch map: 			6. Bore hole dia. 11 in. Completion date _____ Well depth 100 ft. 9-8-77		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material pvc Height: Above or below _____ Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 100 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 237		
			10. Screen: Manufacturer's name _____ CertainTeed Type pvc Dia. _____ Slot 1/16 Length 20' Set between 80 ft. and 100 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
Top soil			11. Static water level: _____ mo./day/yr. 22 1/2 ft. below land surface Date 9-8-77		
Gray clay			12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Fine sand & clay			13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 9-8-77		
Brown sandy clay			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade		
Sand & gravel			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Brown clay			16. Nearest source of possible contamination: ft. 100 Direction North Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No		
Sand & gravel			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed Sandy Kilgore Date 9-9-77 Authorized representative		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

21-1200-22 SW SE NW
T
R
Sec
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5