


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T		R		EW		sec	1/4	1/4	1/4	No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

County	Township name	Fraction	Section number	Township	Range number
Stafford	Byron	CSW $\frac{1}{4}$	23	T21S	R12W
1 Location of well: Distance and direction from nearest town or city: 9 mi. North of Hudson, Kansas Street address of well location if in city:			3 Owner of well: Austin Widener Address: Hudson, Kansas		
Locate with "X" in section below: 			Sketch map:		
2			4 Well depth: <u>140</u> ft. Date of completion <u>8-14-75</u> Well diameter <u>24</u> in.		
Type and color of material			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Sand			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Brown & gray clay			7 Casing: Material <u>Steel</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>100</u> ft. depth! Weight <u>30.3</u> lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Sand			8 Screen: Manufacturer <u>Doerr</u> Type <u>Double-slot</u> Dia. <u>16"</u> Slot gauge <u>1/8</u> Length <u>40'</u> Set between <u>100</u> ft. and <u>140</u> ft. Fittings: <u>3/8-2</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u> </u>		
Sandy clay & limestone			9 Static water level: <u>33</u> ft. below land surface Date <u>8-14-75</u>		
Sand & gravel			10 Pumping level below land surfaces: <u>N/C</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.		
Brown clay			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
Sand, gravel & clay streaks ^x at 131' & 135'			12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> <input type="checkbox"/> Inches above grade		
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.		
			14 Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. <u>185</u> Business name <u> </u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>8-14-75</u> Authorized representative		