1. Location of well:

County

Stafford

WATER WELL RECORD KSA 82a-1201-1215

1/4 **XNE** 1/4

Center

Section number

23

Fraction

1/4

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

12

Range number

\$

Township number

21

2. Distance and direction from nearest town or city:	3. Owner of well:	Mo	onte Widener
12 miles Northeast of Seward, KS Street address of well location if in city:	R.R. or street: Ro		oute 3
Sheet dudiess of well foculton in an only:	City, state, zip co	ode: Hi	udson, KS 67545
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>24</u> in. Completion date <u>5-27-77</u> Well depth <u>140</u> ft.
		:	7Cable toolRotaryDrivenDugHollow rodJettedBoredXReverse rotary 8. Use:DomesticPublic supplyIndustryX_IrrigationAir conditioningStock
S S S S S S S S S S S S S S S S S S S			LawnOil field waterOther 9. Casing: Materialstee THeight: Above or below Threaded WeldedX
ı→ 1 Mile → I			Dia.16 in. to 80 ft. depth Wall Thickness: inches or
5. Type and color of material	From	То	Diain. toft. depth gage No7 ga。 10. Screen: Manufacturer's name Doerr
Sand	0	14	Type BEEDouble-slota 16"
Sandy clay and sand	14	55	Set between 80 ft. and 140 ft.
Brown & white clay & limestone	55	76	
Sand & gravel & clay streaks	76	97	11. Static water level: mo./day/yr. 37 ft. below land surface Date 5-27-77
Gray clay	97	102	12. Pumping level below land surfaces: Not Checked ft. after hrs. pumping g.p.m.
Sand & gravel & thin clay at 112'-136'	102	140	ft. after hrs. pumping g.p.m.
			Estimated maximum yieldg.p.m. 13. Water sample submitted:mo./day/yr.
			Yes X No Date MARKET
			14. Well head completion:
			Pitless adapter12_ Inches above grade
			15. Well grouted? <u>yes</u> With: X Neat cement Bentonite Concrete
			Depth: From 0 ft. to ft.
			16. Nearest source of possible contamination: Field ft Direction Type
			Well disinfected upon completion? YesX No
			17. Pump: Manufacturer's name Berkeley (Used)
			Model number <u>10KBM-7</u> HP <u>50</u> Volts <u>46</u> 0
			Length of drop pipe 70 ft. capacity 800 g.p.m.
			Type: Submersible X Turbine
			Jet Reciprocating
(Use a second sheet if needed)			Centrifugal Other
18. Elevation: 19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
This report is late EE due to log being lost.			is true to the best of my knowledge and belief.
Hill			Business name License No.
Slope			Address Great Bend, AS 67530
Upland Valley			