

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction 1/4 1/4 CSE 1/4	Section number 27	Township number T 21 S R 12 E/W	Range number
2. Distance and direction from nearest town or city: 8 miles Northeast of Hudson, KS Street address of well location if in city:				3. Owner of well: Dennis Siefkes R.R. or street: Route 3 City, state, zip code: Hudson, KS 67545		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 24 in. Completion date: XXXXXX Well depth 120 ft. 12-7-76		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia 16 in. to 60 ft. depth Wall Thickness: inches or Dia 16 in. to 90 ft. depth gage No. 7 ga.		
				10. Screen: Manufacturer's name Doerr Type double-slot Dia. 16" Slot/gauze 1/8" Length 50' Set between 60 ft. and 80 ft. 90 ft. and 120 ft. Gravel pack? yes Size range of material 3/8-200		
				11. Static water level: 14'6" ft. below land surface Date 10-1-76 mo./day/yr.		
				12. Pumping level below land surfaces: N7C ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: 14'6" ft. below land surface Date 10-1-76 mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: ____ Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
(Use a second sheet if needed)				17. Pump: ____ Not installed Manufacturer's name Peerless Pump Model number 12MB-5 HP 60 Volts 460 Length of drop pipe 80 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip., Inc. 185 Business name License No. 12-8976 Address Great Bend, KS 67530 Signed D. W. [Signature] Date 12-8-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5