

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction nw 1/4 nw 1/4 nw 1/4	Section number 6	Township number T 21 S	Range number R 13 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: H-30 Drlg. Inc. R.R. or street: 200 N. Main City, state, zip code: Wichita, Ka.			
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 8 in. Completion date _____ Well depth 47 ft. 12-14-77			
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material _____ Height: Above or <input checked="" type="checkbox"/> Below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.82 lbs./ft. Dia. 5 in. to 47 ft. depth Wall Thickness inches or Dia. _____ in. to _____ ft. depth gage No. Sch 40			
			10. Screen: Manufacturer's name Jetstream Type pvc Dia. 5" Slot/gauze 1/32" Length 20' Set between 27 ft. and 47' ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"			
			11. Static water level: _____ mo./day/yr. 14 ft. below land surface Date 12-14-77			
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: oil ft. 60 Direction S Type test Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
			17. Pump: _____ Not installed Manufacturer's name Goulds Model number utm HP 3 Volts 230 Length of drop pipe 32 ft. capacity 45 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name License No. Address R2 Great Bend, Ks. Signed Kelly P. So Date 8-16-79 Authorized representative				