


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stafford	Fraction NW 1/4 SW NE 1/4 SW 1/4	Section number 31	Township number T 21 S	Range number R 13 E W
2. Distance and direction from nearest town or city: Street address of well location if in city: Seward, KS			3. Owner of well: City of Seward R.R. or street: c/o Lloyd Morton City, state, zip code: Seward, KS 67577		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>6</u> in. Completion date <u>10-27-77</u> Well depth <u>80</u> ft.
top soil			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
brown and white clay			3	23	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other Fire
sand			23	32	9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> X RMP <input type="checkbox"/> PVC <input type="checkbox"/> Dia. <u>2 1/2</u> in. to <u>60</u> ft. depth Weight <u>.63</u> lbs./ft. Wall Thickness: <u>inches</u> or <u>gauge No. .110</u>
sandy clay and sand streaks			32	55	10. Screens: Manufacturer's name Peerless Type PVC Dia. <u>2 1/2</u> " Slot/gauge <u>1/8</u> Length <u>20</u> " Set between <u>60</u> ft. and <u>80</u> ft. Gravel pack? yes Size range of material <u>3/8-200</u>
sand and gravel			55	80	11. Static water level: <u>9' 6"</u> ft. below land surface Date <u>10/27/77</u> mo./day/yr.
					12. Pumping level below land surfaces: NC ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
					13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: Field ft. ____ Direction ____ Type Field Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip., Inc. Business name Great Bend, KS Lic. No. 185 Address 10-28 Signed O.W. Clarke Date 10-28 Authorized representative		

2 L 13 3 L NE NW SW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5