

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stafford	Fraction ne 1/4 sw 1/4 # 1/4	Section number 31	Township number T 21 S R 13W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Melvin Nuss R.R. or street: 3825-19 City, state, zip code: Great Bend, Ks.		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 30 in. Completion date _____ Well depth 105 ft. 12-23-77		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material stl Height: Above XXXX Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 30 lbs./ft. Dia. 16 in. to 105 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 3/16"		
			10. Screen: Manufacturer's name _____ Doerr Type steel Dia. 16" Slot/gauze 1/8" Length 40' Set between 65 ft. and 105 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-3/4"		
			11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 12-23-77		
			12. Pumping level below land surfaces: 44 ft. after 4 hrs. pumping 1200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: _____ oil ft. 1500 Direction n Type well Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
			17. Pump: _____ Not installed Manufacturer's name Goulds Model number 12 jh HP 50 Volts 460 Length of drop pipe 80 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name _____ License No. _____ Address R2 Great Bend, Ks. Signed Kelley Duce Date 8-20-77 Authorized representative		

2-1-30
 3-1-30
 Sec
 1/4 1/4 1/4
 Nuss
 Duce

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5