USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215



Kansas Department of Health and Environment Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number	
1. Location of well:	Pawnee	NW 1/4 SW 1/4 SE	1/4	8		т 21 s	R 15 €	
2. Distance and direction from nearest town or city: Approx. 7½ miles NE of Larned, KS Street address of well location if in city:				ner of well: street: tate, zip code:		H. Lee Turner Route 1 Great Bend, KS 67530		
4. Locate with "X" in section below: Sketch map:					.oue:		Completion date 6-11-79 ump Set 7-5-79	
Mie	NE I					8. Use: Domestic Pu	Bored X Reverse rotary	
SW X - SE					Lawn Oil field water Other 9. Casing: Material steel Height: Above or below Threaded Welded Surface 12 in. RMP PVC Weight 30 . 3 lbs ./ft.			
S I——— 1 Mile —————						Dia 16 in to 20 ft. depth Wall Thickness: inches or		
5. Type ond color of material				From	То	Dia in. to ft. dep 10. Screen: Manufacturer's n		
Sandy top soil				0	3	Type Double-slot	_ Dia16"	
Gray clay				3	8	Slot gauze 1/8!! Length 20! Set between 20 ft. and 40 ft.		
Sand & gravel				8	34	ft. a	indft. inge of material 3/8-200	
Brown clay, cement, sand & dakota clay				34	60	11. Static water level: ft. below land sur	mo./day/yr. face Date 6-11-79	
						12. Pumping level below land 15½ ft. after 1½ 1	d surfaces: XXXXX ors. pumping 700 g.p.m.	
						ft. after h	nrs. pumping g.p.m.	
						13. Water sample submitted: YesX No	mo./day/yr. Date	
						14. Well head completion: Pitless adapter 1	2 Inches above grade	
						15. Well grouted? Yes With: X Neat cement Bentonite Concrete Depth: From 0 ft. to 10 ft.		
						16. Nearest source of possible	Туре	
						Well disinfected upon comple	Not installed	
(Use a second sheet if needed)						Manufacturer's name Peerless Pump Co. Model number 12LB-1 HP 60 Volts Length of drop pipe 35 ft. capacity 700g.p.m. Type: Submersible X Turbine		
						Submersible Jet Centrifugal	Reciprocating Other	
18. Elevation: 19. Remarks: 315 (Z					L	20. Water well contractor's o	certification:	
\950 Turner - Mull #4						This well was drilled under m is true to the best of my know	′ ' ' I	
Topography:						Business name Great Bend KS 67530		
Slope Upland						Address Great Bend	7-27-79	
Valley						Authorized rep	resentative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5