

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Pawnee		Fraction SW 1/4	Section number 1	Township number 21	Range number 16	E/W E/W
1. Location of well: 3W 4S 1S of Pawnee Rock Street address of well location if in city:			3. Owner of well: Dennis Augustine R.R. or street: 908 Stark Dr. City, state, zip code: Larned, Ks.			
2. Distance and direction from nearest town or city:			4. Locate with "X" in section below: Sketch map: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div>			
5. Type and color of material			From	To	6. Bore hole dia. 8 7/8 Completion date _____ Well depth 48 ft. 12-1-76	
Top Soil			0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Black Clay			2	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sand Gravel			15	48	9. Casing: Material pvc Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 160 lbs./ft. Dia. 4 in. to 48 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1	
Brown Clay			48	50	10. Screen: Manufacturer's name _____ R/B Type pvc Dia. 4 Slot/gauze 1/16 Length 20 Set between _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____	
					11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 12-1-76	
					12. Pumping level below land surfaces: 17 ft. after 2 hrs. pumping 65 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 65 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12-1-76	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 70 Direction S Type septic Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Media Dodson Date 12/2 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5