

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Pawnee		Fraction C 50		Section number 12		Township number 21		Range number 16		E.W. 0	
2. Distance and direction from nearest town or city: 4 W of Pawnee Rock N side Rd					3. Owner of well: Mick Marlett R.R. or street: City, state, zip code: Larned, KS						
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div>					Sketch map: <div style="text-align: center;">NW NE SW SE X</div>						
5. Type and color of material					From		To		6. Bore hole dia. 2 1/2 in. Completion date Well depth 58 ft. 8-5-76		
Top Soil					0		3		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Black & Brown Clay					3		6		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand and Gravel					6		57		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 58 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 7		
Brown Clay					57		80		10. Screen: Manufacturer's name Dockers Type Steel Dia. 16 Slot gauge 3/16 Length 18 Set between 40 ft. and 58 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 42 3/4 3/8		
									11. Static water level: <input type="checkbox"/> mo./day/yr. 12 ft. below land surface Date 6-9-76		
									12. Pumping level below land surfaces: 13 ft. after 1 hrs. pumping 800 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 850 g.p.m.		
									13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-9-76		
									14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
									15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
									16. Nearest source of possible contamination: ft. 14 Direction W Type Correl Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
									17. Pump: Manufacturer's name WLR Not installed Model number 3-KBN-12 HP 60 Volts Length of drop pipe 45 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)											
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencranz - Bemis 134 Business name Great Bend KS License No. Address Frederic Roden Date 9/30/76 Signed Frederic Roden Authorized representative						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5