

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 31	Township number T 21 S R 16 E/W	Range number		
2. Distance and direction from nearest town or city: 1/2 W			3. Owner of well: Luther Wells					
Street address of well location if in city: Larned, KS			City, state, zip code: R. 3 Larned, KS.					
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:					
5. Type and color of material			From	To				
			Top Soil-clay Sand Rock			0	125	
						125	150	
6. Bore hole dia. 8 in. Completion date 5-19-76			Well depth 150 ft.					
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug			<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry			<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock					
<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other								
9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/>			Height: <input checked="" type="checkbox"/> Above or below Surface 12 in. Weight <input type="checkbox"/> lbs./ft.					
Dia. 5 in. to 150 ft. depth			Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth					
10. Screen: Manufacturer's name MPI			Type PVC Dia. 5"					
Slot/gauze 1/8" Length 20'			Set between 130 ft. and 150 ft.					
Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"								
11. Static water level: 80 ft. below land surface			Date 5-19-76					
12. Pumping level below land surfaces:								
13. Water sample submitted:			mo./day/yr.					
Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date								
14. Well head completion:								
15. Well grouted? <input checked="" type="checkbox"/>								
With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete								
Depth: From 0 ft. to 10 ft.								
16. Nearest source of possible contamination:								
ft. 90 Direction E Type sewer								
Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No								
17. Pump:								
Manufacturer's name Goulds			Not installed					
Model number 13EM HP 1 Volts 230								
Length of drop pipe 140 ft. capacity 15 g.p.m.								
Type:								
<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine								
<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating								
<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other								
18. Elevation:			19. Remarks:					
Topography:								
<input type="checkbox"/> Hill								
<input type="checkbox"/> Slope								
<input checked="" type="checkbox"/> Upland								
<input type="checkbox"/> Valley								
20. Water well contractor's certification:								
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.								
Business name Kelly's Water Well Ser License No. 186								
Address R 2 Great Bend, KS								
Signed _____ Date _____			Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

21 160 31 SWSUSE 1/4 1/4 1/4