

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 34	Township number T 21 S R 16 NW	Range number
2. Distance and direction from nearest town or city: 1/2 NE			3. Owner of well: Geo. Weiman			
Street address of well location if in city: Larned, KS			City, state, zip code: KL Larned, KS			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date 2-28-76 Well depth <u>92</u> ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil - Clay			0	20	9. Casing: Material PVC Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>72</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>	
Sand - gravel - clay			20	65	10. Screen: Manufacturer's name MPI Type PVC Dia. <u>5"</u> Slot/gauze <u>1/8"</u> Length <u>20'</u> Set between <u>42</u> ft. and <u>92</u> ft. <u> </u> ft. and <u> </u> ft.	
clay			65	70	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4-3/4"</u>	
Sand Rock			70	92	11. Static water level: <u> </u> mo./day/yr. <u>27</u> ft. below land surface Date 2-28-76	
					12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>25</u> g.p.m.	
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u> </u> inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>4</u> ft. to <u>14</u> ft.	
					16. Nearest source of possible contamination: <u>Septic</u> ft. <u>65</u> Direction <u>S</u> Type <u>Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds</u> Model number <u>13EM</u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>42</u> ft. capacity <u>15</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation: <u>1991'</u>		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Kellys Water Well Serv</u> Business name <u>R2 Great Bend, KS</u> License No. <u> </u> Address <u> </u> Signed <u>Kelly Price</u> Date <u>3-3-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5