


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 11	Township number T 21	Range number S R 2
2. Distance and direction from nearest town or city: Street address of well location if in city:	Moundridge, Mo. 3 N. 1/2 E. S side		3. Owner of well: R.R. or street: City, state, zip code: Richard Lalle R.R. 2 Moundridge, Mo.		
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 8 in. Completion date 5-20-76 Well depth 60 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top Soil	0		1		9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 10 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. 5 in. to 60 ft. depth gauge No. 14"
Red Buff clays	1		12		10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauze 1/32 Length 10' Set between 50 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 1/4"
Dark sandy clays	12		22		11. Static water level: 19 ft. below land surface Date 5-20-76 mo./day/yr.
Line rock - sandy clays	22		27		12. Pumping level below land surfaces: 24 ft. after 142 hrs. pumping 8 g.p.m. ft. after 142 hrs. pumping 8 g.p.m. Estimated maximum yield 30 g.p.m.
Line rock.	27		29		13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 5-20-76 mo./day/yr.
Fine sands	28		29		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
Line rock & white clay	29		42		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.
Very fine sand & clay layers.	42		56		16. Nearest source of possible contamination: ft. 175 Direction N.W. Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Coarse sand & gravel	56		59 1/2		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Blue & Red. shales	59 1/2		61		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Peterson Bros 138 Business name License No. Address Box 150 Lendberg, Mo. Signed Willy Peterson Date 7-31-76 Authorized representative
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	Mr. Lalle will pour concrete slab for pump house. someone else putting in pump				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5