


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>McPherson</u>	Township name <u>Mound</u>	Fraction <u>SW 1/4 - SE 1/4</u>	Section number <u>26</u>	Town number <u>T-21-S</u>	Range number <u>2 W</u>		
Distance and direction from nearest town or city: <u>1/2 SE of Moundridge</u>			3 Owner of well: <u>Ron Lucore</u> Address: <u>Box 71 Moundridge, Kans</u>					
Street address of well location if in city:								
Locate with "X" in section below: N  S 1 Mile			Sketch map:			4 Well depth: <u>45</u> ft. Date of completion <u>2-27-75</u> Well diameter <u>8"</u> in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>					
			7 Casing: Material <u>PVC</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>15</u> in. Diam. <u>5"</u> Weight <u> </u> lbs./ft. <u> </u> <u>5</u> in. to <u>45</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No <u> </u> in. to <u> </u> ft. depth					
			8 Screen: <u>Artisan Lead</u> Manufacturer <u>POC</u> Dia. <u>5"</u> Type <u>POC</u> Slot/gauze <u>7/32</u> Length <u>10 ft</u> Set between <u>35</u> ft. and <u>45</u> ft. Fittings: <u>48"</u> Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material <u> </u>					
			9 Static water level: <u>20</u> ft. below land surface Date <u>2-27-75</u>					
(use a second sheet if needed)			10 Pumping level below land surfaces: <u>40</u> ft. after <u>1 1/2</u> hrs. pumping <u>2.5</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2</u> g.p.m.		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>			
			12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>15"</u> inches above grade		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>5</u> ft. to <u>15</u> ft.			
			14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			16 Remarks: elevation Topography: <u>Surface Area slopes away to southwest from well area</u> <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>PeTerson Bros INC</u> <u>138</u> Business name License No. Address <u>Box 150 Hindsbury, Kans</u> Signed <u>Wallace Peterson</u> Date <u>2-28-75</u> By <u>D.P.</u> Authorized representative		