

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as 28-215-20

changed to SE NE SW, 28-215-20W

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

verification method: written description, city map on internet,
and Burdett 1:24,000 topo. map. initials: DRd date: 6/15/2001

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

Sent to Leonard 5-27-77

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PAWNEE	Fraction $\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$	Section number 28	Township number T 21 S R 20 E/W
2. Distance and direction from nearest town or city: CORNER OF			3. Owner of well: CITY OF BURDETT		
Street address of well location if in city: LOCUST + MICHIGAN			City, state, zip code: BURDETT KANSAS 67523		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date APRIL 77 Well depth 190 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
BLACK TOP SOIL		0	1	9. Casing: Material <input type="checkbox"/> Height: Above or below 48 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 48 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 320	
BROWN CLAY		2	30	10. Screen: Manufacturer's name JTL Type RMP Dia. 6" Slot/gauze 1/16 Length 50' Set between 140 ft. and 190 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #1	
RED SANDSTONE		30	35	11. Static water level: 68 ft. below land surface Date 9-17-76	
GREY CLAY		35	37	12. Pumping level below land surfaces: 74 ft. after 12 hrs. pumping 30 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 120 g.p.m.	
RAINBOW CLAY		37	68	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
BROWN SANDSTONE		68	93	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade	
BLUE SHALE + SOAPSTONE		93	143	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6' ft. to 26 ft.	
SANDSTONE (GOOD CLEAN)		143	193	16. Nearest source of possible contamination: CITY ft. 140 Direction EAST Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
RED CLAY		193	200	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name REDA Model number 9055E HP 5 Volts 220 Length of drop pipe 147 ft. capacity 75 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILL Business name HANSTON KANSAS License No. 1/4 Address 1/4 Signed Dean Waterhouse Date 8 Authorized representative 9-17-77	
19. Remarks: WELL GRANVEL PACKED UP TO 140 FT THEN CEMENTED WITH 10 SX CEMENT PACKED TO -26 FT CEMENTED TO -6 FT TOP 22 FT DRILLED WITH 10" BIT					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5