

BURDETT


T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

BBA

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

1 Location of well:	County HODGEMAN	Township name MARENA	Section number 23	Town number 21	Range number 21
Distance and direction from nearest town or city: 4 1/2 MI WEST 2 MI NORTH 1/8 MI EAST OF BURDETT			3 Owner of well: ELMER SELFRIDGE Address: BURDETT KANSAS		
Locate with "X" in section below: 		Sketch map:		4 Well depth: 130 ft. Date of completion 2-5-75 Well diameter 16 in.	
2 Type and color of material		From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
TOPSOIL + YELLOW CLAY		0	85	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
SAND + GRAVEL - LOOSE + COARSE		85	129	7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. Diag. Weight 7.96 lb./ft. 16 in. to 90 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
BLUE SHALE		129	B0	8 Screen: WABROWN Manufacturer ENTERPRISES Type STEEL Dia. 16 Slot/gauze 1/8 Length 40 Set between 90 ft. and 130 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 2 DOWN	
BROCK 129' RWH				9 Static water level: 56 ft. below land surface Date 10-MARCH	
56				10 Pumping level below land surfaces: 72 ft. after 4 hrs. pumping 1250 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2000 g.p.m.	
73' sat thick				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
ALLUVIUM				12 Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade	
				13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From _____ ft. to _____ ft.	
				14 Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number _____ HP 50 Volts 440 Length of drop pipe 120 ft. capacity 1500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILLING Business name _____ License No. 243 Address MANSTON KANSAS Signed Dean Waterhouse Date 15-June-75 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		2122 129 2093 v			