

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

BURDETT

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDB

1. Location of well: County: Hodgman		Fraction: NW 1/4 SE 1/4	Section number: 23	Township number: T 21 S R 21 E NW	Range number: 21
2. Distance and direction from nearest town or city: 2 N - 4 W - 3/4 S of		3. Owner of well: Ed Eakin			
Street address of well location if in city: Burdette		City, state, zip code: Burdett, Ks, 66909			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 10 29/32 in. Completion date 10-15-76 Well depth 108 ft.	
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
∅ Top Soil		0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		3	43	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 108 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7	
Blue Sand and Gravel		43	71	10. Screen: Manufacturer's name Johnson and Doerrs Type Steel Dia. 16 Slot/gauge 3/16 Length 14 & 18 Set between 18 @ 71 1/2 ft. and 89 1/2 ft. 14 @ 93 ft. and 108 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____	
Good Clean Sand and Gravel		71	87	11. Static water level: _____ mo./day/yr. 45 ft. below land surface Date 8-17-76	
Clay		87	87 1/2	12. Pumping level below land surfaces: 48 ft. after 1 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1200 g.p.m.	
Good Clean Sand and Gravel		87 1/2	89	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-17-76	
Clay		89	90	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
Good Clean Gravel		90	95	15. Well grouted? _____ With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay		95	100	16. Nearest source of possible contamination: ft. 1/2 Direction NW Type corrall Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Good clean Sand and Gravel		100	109	17. Pump: _____ Not installed Manufacturer's name W.L.R. Model number 3 BHC 12 HP 60 Volts _____ Length of drop pipe 90 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Fire		109		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenrants Bemis 134 License No. _____ Business name _____ Address Great Bend, Ks. 67530 Signed Fredia Baker Date 11/8 Authorized representative	
18. Elevation:		19. Remarks: 2122 109 20134			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

21 21 23 NW 1/4 SE