

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

BURDETT

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

AA

1. Location of well: County: <b>Hodgeman</b>		Fraction: <b>SE 1/4 ne 1/4 ne 1/4</b>		Section number: <b>24</b>		Township number: <b>T 21 S R 21</b>		Range number: <b>EW</b>	
2. Distance and direction from nearest town or city: <del>2n-5w- of Burdett</del> Street address of well location if in city: <b>2-N 8-E 5 1/4-N of Hanston, Ks</b>				3. Owner of well: <b>Eldred Lewis</b> R.R. or street: <b>Scenic Drive</b> City, state, zip code: <b>Larned, Ks. 67550</b>					
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. <b>29</b> in. Completion date _____ Well depth <b>140</b> ft. <b>3-5-76</b>					
5. Type and color of material				From		To		7. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top soil				0		3		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Hard clay				3		21		9. Casing: Material <b>steel</b> Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. <b>16</b> in. to <b>140</b> depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>7</b>	
Soft clay				21		32		10. Screen: Manufacturer's name <b>Doerrs</b> Type <b>steel</b> Dia. <b>16</b> Slot/gauge <b>3/16</b> Length <b>52</b> Set between <b>88</b> ft. and <b>140</b> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>3/4-3/8-1/2</b>	
Sandy clay				32		54		11. Static water level: _____ mo./day/yr. <b>55</b> ft. below land surface Date <b>10-23-75</b>	
Fine sand w/ clay				54		60		12. Pumping level below land surfaces: <b>70</b> ft. after <b>2</b> hrs. pumping <b>800</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1100</b> g.p.m.	
Sand				60		74		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <b>10-23-75</b>	
Clay				74		83		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
Gravel				83		97		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
Clay				97		104		16. Nearest source of possible contamination: ft. <b>2 mi</b> Direction <b>NE</b> Type <b>gas well</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Good sand				104		109		17. Pump: _____ Not installed Manufacturer's name <b>W.L.R</b> Model number <b>2-12hnd</b> _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay				109		112		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rosencrantz-Bemis 134</b> Business name <b>Great Bend, Ks.</b> License No. _____ Address _____ <input checked="" type="checkbox"/> Signed <b>S. K. Moore</b> Date <b>6-19-77</b> Authorized representative	
Good clean sand & gravel				112		139			
Fire clay				139		140			
Brock 139' RR. 55' 84' sat thick (Use a second sheet if needed) in Alluvium									
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <b>2121 (TOP)</b> <b>139</b> <b>1762</b>							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5