

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HODGEMAN	Fraction SW NW 1/4NW 1/4 SE 1/4	Section number 25	Township number T 21	Range number S R 21	E/W E/W
2. Distance and direction from nearest town or city: 3-1/2 mile W west		Owner of well: RAYMOND BAUER		Street address of well location if in city: & 1/2 mile north of Burdett			
City, state, zip code: BURDETT, KANSAS 67523							
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. #30 in. Completion date Aug. 7 1980			
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
black topsoil		0	2	9. Casing: Material steel Height: Above or below land Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 47C Weight 3.2 lbs./ft. Dia 16 in. to 16 ft. depth Wall Thickness: inches or Dia. 16 in. to 16 ft. depth gage No. 219			
brown clay		2	38	10. Screen: Manufacturer's name W.A. BROWN ENTERPRISES Type steel Dia. 16" Slot/gauze 17% open Length 20' Set between 47 ft. and 127 ft. ft. and 127 ft.			
fine sand		38	50	Gravel pack? yes Size range of material 1/4" to 3/8"			
sand		50	65	11. Static water level: 45 ft. below land surface Date 5/4/80 mo./day/yr.			
tan clay		65	75	12. Pumping level below land surfaces: 64 ft. after 6 hrs. pumping 1300 g.p.m. 58 ft. after 2 hrs. pumping 725 g.p.m. Estimated maximum yield 1800 g.p.m.			
sand & some clay		75	96	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____ mo./day/yr.			
blue clay		96	110	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
red sand		110	124	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
blue shale		124	140	16. Nearest source of possible contamination: old well ft. 60 Direction west Type well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: Johnston Not installed Manufacturer's name Western Valve & Roller Model number S-1100 HP 270 Volts 460 Length of drop pipe 124 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation:	19. Remarks: REF # 10 WELL PACKED WITH SIZE 1/2 DOWN WITH 30% #2			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 243 DEAN WATER-HOUSE DRILLING Business name License No. _____ Address R.R. 1 BOX 72 HANSTON, KS. 67523 Signed Dean Waterhouse Date 5/7/81 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5