

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

BURDETT

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDA

1. Location of well:		County Hodgeman	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 35	Township number T 21 S R 21	Range number EW
2. Distance and direction from nearest town or city: 3SW on Hiway 156 1/4 N of Burdett			3. Owner of well: Charlie Dresie R.R. or street: RR 1 City, state, zip code: Jetmore, Kansas 67854			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 80 ft. 6-1-79		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material plts Height Above or below Threaded _____ Welded 81 Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 61 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250		
Topsoil		0	2	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in <input checked="" type="checkbox"/> Slot gauze (1/16) Length 20 ft Set between 60 ft. and 80 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4-1/8		
Clay brown		2	35	11. Static water level: _____ mo./day/yr. 42 ft. below land surface Date 6-1-79		
Sand		35	50	12. Pumping level below land surfaces: 45 ft. after 1 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.		
Clay white		50	60	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sand		60	73	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
Clay		73	74	15. Well grouted? yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.		
Sand		74	80	16. Nearest source of possible contamination: ft. 100 Direction nw Type Stock Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay		(80)		17. Pump: _____ Not installed Manufacturer's name Aeromotor Model number SD1250 HP 1/2 Volts 230 Length of drop pipe 63 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
Brock 80'				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros Drilling Business name _____ License No. _____ Address Jetmore Ks 130 Signed Dale Knoefler Date 6-16-79 Authorized representative		
42' 38' sat thick in Alluvium				18. Elevation: _____ 19. Remarks: 2112 80 2032 TOPO		
(Use a second sheet if needed)				18. Elevation: _____ 19. Remarks: _____		

T 21 S R 21 E
Sec 35 NE SE SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5