


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HODGEMAN	Fraction SE 1/4 NE 1/4	Section number 15	Township number T 21 S	Range number R 22 E/W
2. Distance and direction from nearest town or city: 7 mi. north and 1/4 mi. west from Hanston Street address of well location if in city:			3. Owner of well: Mrs. Gus Lingenfelder R.R. or street: City, state, zip code: Burdett, Kansas 67523			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 8 in. Completion date 7/30/79 Well depth 50 ft.	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 26 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 30 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 2001b	
					10. Screen: Manufacturer's name JET STERAM Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 30 ft. and 50 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #1	
					11. Static water level: _____ mo./day/yr. 32 ft. below land surface Date 7/11/79	
					12. Pumping level below land surfaces: 37 ft. after 1 hrs. pumping 6 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 6 1/2 7 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 26 Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: dug ft. 120 Direction east Type well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse Drilling 243 Business name License No. Address Hanston, Kansas Signed Dean Waterhouse Date 8/7 Authorized representative 8/29		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Q 1 2 2 2 1 5
 T R W E
 Sec 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5