

JETMORE NE

T	R	EW	sec 1/4	1/4	1/4	No.
---	---	----	---------	-----	-----	-----

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

AAK

1 Location of well:		County HODGEMAN	Township name VALLEY NE 1/4	Fraction SW NE NE	Section number 11	Town number 21	Range number 23
Distance and direction from nearest town or city: 11 N 5 EAST				3 Owner of well: JOHN SMITH			
Street address of well location if in city: FROM JETMORE				Address: JETMORE KANSAS			
Locate with "X" in section below:		Sketch map:		4 Well depth: 33 ft. Date of completion: 21 NOV Well diameter 5 in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
				7 Casing: Material PLASTIC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam 5 in. to 23 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 23 ft. depth			
2		Type and color of material		From	To	8 Screen: Manufacturer J+L Type STYRENE Dia. 5" Slot/gauze 1/4" Length 10' Set between 23 ft. and 33 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8" - 3/16"	
		TOPSOIL		0	3	9 Static water level: 23 ft. below land surface Date 3-NOV-75	
		SANDY TAN CLAY + WHITE ROCK		3	12	10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 3 g.p.m.	
		MAZE COLORED CLAY		12	26	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
		FINE SAND		24	29	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 4 inches above grade	
		SHALE		(29)	35	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 11 ft.	
		BROCK 29'				14 Nearest source of possible contamination: ft. _____ Direction WILL Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		23				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name CLAYTON MATH Model number _____ HP _____ Volts _____ Length of drop pipe 29 ft. capacity 3 g.p.m. Type: 2 1/4" CYLINDER <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		6' sat thick				16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 2335 29 2306 TOPO	
		in Alluvium				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERKOSB PRELLING Business name _____ License No. _____ Address HANSTON KANSAS Signed Dean Waterkosb Date 24-NOV-75 Authorized representative	

21 23 W 11 CS 1/2 NE