

JETMORE NE

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCC

1. Location of well:		County Hodgeman	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 25	Township number T 21 S	Range number R 23	E/W
2. Distance and direction from nearest town or city: of Jetmore Street address of well location if in city:				3. Owner of well: Martin Bamberger R.R. or street: City, state, zip code: Jetmore, Kansas 67854			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 11-22-75 Well depth 390 ft.			
		<p>well Pasture</p> <p>House</p>		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Topsoil		0		5		9. Casing: Material: steel Height: (Above) or below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP: PVC Weight: 11 lb./ft. Dia. 4 1/2 in. to 360 ft. depth; Wall Thickness: inches or Dia. in. to ft. depth; gage No.	
Yellow clay		5		27		10. Screen: Manufacturer's name Doerr Type Dia. 4 1/2 Slot/gauze 1/16 Length 30 Set between 360 ft. and 390 ft. ft. and ft. Gravel pack <input checked="" type="checkbox"/> yes Size range of material 1/8	
Blue shale		27		260		11. Static water level: mo./day/yr. 170 ft. below land surface Date 11-21-75	
White clay		260		310		12. Pumping level below land surfaces: 195 ft. after 6 hrs. pumping 12 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m.	
Red clay		310		340		13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
White clay sandy		340		360		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
Sand rock		360		390		15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 20 ft.	
BROCK 5' 2 1/2"						16. Nearest source of possible contamination: House ft. 250 Direction S Type Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
CRETACEOUS WELL						17. Pump: Not installed Manufacturer's name Goulds Model number 7EH1041 HP 1 Volts 230 Length of drop pipe 294 ft. capacity 8 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Concrete slab was installed by Owner 2319 TOPD		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros Drilling Business name Jetmore License No. 130 Address Dale Knoefler Date 12-23-75 Signed Dale Knoefler Authorized representative			

21
22
23
24
25
SW
SW
NW
NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5