

JETMORE NW

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCC

1. Location of well:		County HODGEMAN	Fraction SW/4 SW 1/4 NW 1/4	Section number 24 LYNN	Township number T 21 S	Range number R 24 E/W
2. Distance and direction from nearest town or city 7 mi. north 1 mi. west 1/2 mi. north from Jetmore, Kansas Street address of well location if in city:			3. Owner of well: Goebel R.R. or street: RR City, state, zip code: Jetmore, Kansas 67854			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 75 ft. 12/4/79		
				7. <input checked="" type="checkbox"/> Cable tool Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
brown clay		0	10	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200 plus		
sand fine		10	50	10. Screen: Manufacturer's name _____ Jet Stream Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 55 ft. and 75 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material # 1		
sand and clay		50	60	11. Static water level: _____ mo./day/yr. 63 ft. below land surface Date 8/1/79		
good clean sand		60	72	12. Pumping level below land surfaces: 67 ft. after 2 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 35-40 g.p.m.		
yellow clay		72	73	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
black shale		73	75	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade		
BROCK 72'				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
63'				16. Nearest source of possible contamination: septic ft. 60 Direction sw Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
9' sat thick				17. Pump: _____ Not installed Manufacturer's name Rada Model number 9D9P051 HP 1/2 Volts 230 Length of drop pipe 70 ft. capacity 9 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
in Og				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse Drilling 243 Business name License No. Address Hanston, Kansas Signed Dean Waterhouse Date 29 Dec 79 Authorized representative		
18. Elevation:		19. Remarks:		(Use a second sheet if needed)		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		2405 76 2333				

T 21 S 24 R 24 Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5