

HORSE THIRT CANYON NE

KC

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

ACC

1. Location of well:		County Hodgeman	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 11	Township number T 21 S R 25 EW	Range number
2. Distance and direction from nearest town or city: 8W, 11N, 1/4E, 1/4N, 1/4E of Jetmore Street address of well location if in city:			3. Owner of well: J. D. Nuss R.R. or street: Jetmore, KS 67854 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>12-15-76</u> Well depth <u>54</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>6</u> in. to <u>34</u> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <u>.188</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Bridge</u> Dia. <u>16</u> Slot/gouze <u>188</u> Length <u>20</u> Set between <u>34</u> ft. and <u>54</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 to 5/8</u>		
Surface		0	3	11. Static water level: <u>31</u> ft. below land surface Date <u>12-17-76</u> mo./day/yr.		
Clay		3	15	12. Pumping level below land surfaces: <u>52</u> ft. after <u>2</u> hrs. pumping <u>350</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>350</u> g.p.m.		
Sand "dry"		15	22	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Clay & Streaks of Sand		22	28	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Clay		28	31	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Med. Sand & Gravel		31	38	16. Nearest source of possible contamination: <u>1/8 mile</u> Direction <u>West</u> Type <u>Oil Well</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Clay		38	41	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>3-8AH</u> HP <u>10</u> Volts <u>480</u> Length of drop pipe <u>50</u> ft. capacity <u>350</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand & Gravel		41	54	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Woofter Drilling, Inc, 343 Business name License No. Address <u>Hwy. 56 Dodge City, KS</u> Signed <u>Michael W. Dwyer</u> Date <u>9/6/76</u> Authorized representative		
Hard Rock		(54)	57			
<u>BRock 54'</u>						
<u>31</u>						
<u>23' sat thick</u>						
<u>in Alluvium</u>						
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	<u>2305</u> <u>5'</u> <u>225'</u> <u>TOPO</u>					

21 250 1/8 SWSA NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5