

*The
Professionals*

MINTER-WILSON DRILLING CO.

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

INCORPORATED

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Arylene Jackson
Bill Cohoon - Tenant
Hodgeman County
7/12/99

Location: NW $\frac{1}{4}$ 20-21-25 - From Kalvesta - 13 miles east, 10 miles north
& 3/4 mile west - Well in corner south
Ro. marker 45 on highway
(offset old well to test hole - 34 ft. west
& 71 ft. south)

Static Water Level - 30'

Test #1

0' to 3' - Top soil
3' to 12' - Brown clay
12' to 14' - Fine sand - loose - took water
14' to 38' - Brown clay
38' to 64' - Fine to medium sand and gravel - 80% coarse white gray rock - loose
64' to 80' - Shale - hard pull down 300

RECEIVED

FEB 07 2000

BUREAU OF WATER