


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County McPHERSON	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 6	Township number T 21 S	Range number R 3 W
X Distance and direction from nearest town or city: Street address of well location if in city:		3.5 1W OF McPHERSON, Ks.		3. Owner of well: NORMAN ENSZ R.R. or street: 570 ONE SPACES R.R. #1 City, state, zip code: INMAN, KS.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 8-4-78 Well depth 90 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	5	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft.		
RED CLAY		5	12	Dia. 4 in. to 80 ft. depth Wall Thickness: inches or Dia. 4 in. to 80 ft. depth gage No. 125 in		
BROWN CLAY		12	31	10. Screen: Manufacturer's name PEERLESS PLASTICS Type PVC Dia. 4" Slot/gauze 1/4 Length 10 ft Set between 80 ft. and 90 ft. Gravel pack? YES Size range of material 1/4 in		
BROWN FINE SAND AND CLAY		31	40	11. Static water level: 40 ft. below land surface Date 8-4-78		
FINE BROWN SAND		40	62	12. Pumping level below land surfaces: 42 ft. after 2 hrs. pumping 15 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m.		
FINE GREY SAND		62	80	13. Water sample submitted: YES No Date		
MEDIUM SANDS		80	90	14. Well head completion: Pitless adapter 12 Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 4000 Direction N Type Cattle Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name License No. Address Box 150 LINDSBORL Ks. Signed Mike Peterson Date 9-2-78 Authorized representative		