

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 27	Township number T 21 S	Range number R 3 E
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W S 1 Mile Sketch-map: N End of Pond Slope WELL				6. Bore hole dia. 12 in. Completion date Well depth 78 ft. 1/15/76		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.23 lbs./ft. Dia. 6 in. to 78 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0255		
				10. Screen: Manufacturer's name Robin-Tech - down slot Type PVC Dia. 6" Slot/gauge 0.64 Length 20" Set between 56 ft. and 76 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/4"		
				11. Static water level: 21 ft. below land surface Date 1/5/76		
				12. Pumping level below land surfaces: 28 ft. after 36 hrs. pumping 70 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 300 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter 12 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 0 ft.		
				16. Nearest source of possible contamination: 0.5 miles ft. 138 Direction West Type Lagoon Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: Manufacturer's name Dempster Model number PVE- HP 2 Volts 230 Length of drop pipe 65' ft. capacity 70 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC # 175 Business name License No. Address Box 26 Heston Signed Paul B. Paul Date 1/16/76 Authorized representative		
19. Remarks:						