


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPHERSON	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 33	Township number T 21 S	Range number R 3 W
2. Distance and direction from nearest town or city: 8 mi. South and 8 mi. WEST OF MOUNDRIIDGE, KS		3. Owner of well: DAVE PENNER R.R. #1		Street address of well location if in city: Moundridge, KS 67107		
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 8 1/2 in. Completion date 10-30-78 Well depth 96 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Top soil		0		5		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay		5		24		9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft.
Sandy brown clay		24		30		Dia. 4 in. to 8 1/2 ft. depth Wall Thickness: inches or Dia. 4 in. to 8 1/2 ft. depth gage No. .25
Gray clay		30		48		10. Screen: Manufacturer's name Peerless Plastics Type PVC Dia. 4" Slot/gauze 1/16 Length 10' Set between 86 ft. and 96 ft. Gravel pack? Yes Size range of material 14
Gray sand (Fine)		48		75		11. Static water level: 50 ft. below land surface Date 10/30/78 mo./day/yr.
Med. gray sand		75		105		12. Pumping level below land surfaces: 50 ft. after 1 hrs. pumping 12 g.p.m. 50 ft. after 1 hrs. pumping 50 g.p.m. Estimated maximum yield 50 g.p.m.
						13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 10/30/78 mo./day/yr.
						14. Well head completion: 12 inches above grade Pitless adapter
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 7 ft. to 14 ft.
						16. Nearest source of possible contamination: ft. 150 Direction SW Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name PETERSON HP 1/2 Volts 115 Model number Box 155 Length of drop pipe 11-17-78 ft. capacity 11-17-78 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name Box 155 LINCOLN, KS License No. 11-17-78 Address Mike Peterson Signed 11-17-78 Date 11-17-78 Authorized representative		