


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

T S B B

1. Location of well:	County HAMILTON	Fraction NW 1/4 NW 1/4 NW 1/4	Section number? 2	Township number T 21	Range number S R 41	E W
2. Distance and direction from nearest town or city: 19 N 2 W? SYRACUSE			3. Owner of well: Terry Boy R.R. or street: N.R.R #1 City, state, zip code: Syracuse Ks. 67878			
4. Locate with "X" in section below: N  W E S 1 Mile			6. Bore hole dia. 7 7/8 in. Completion date 02/20/78 Well depth 1025 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Steel Height: <u>Above or below</u> Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 15 lbs./ft. Dia. 5 1/2 in. to 1025 ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. 219			
			10. Screen: Manufacturer's name Torch perf Type Torch perf Dia. 5 1/2 Slot gauge <u> </u> Length 100 Set between 900 ft. and 1000 ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material CMA 4/8			
			11. Static water level: <u> </u> mo./day/yr. 160 ft. below land surface Date 12-12-78			
			12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield 50 g.p.m.			
			13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 173 ft.			
			16. Nearest source of possible contamination: ft. 5280 Direction EAST Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 8" surface casing set to 173' Deepest Water Well in Hamilton Co. TD 1025'		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zuhon Drilling Co 300 Business name <u> </u> License No. <u> </u> Address Syracuse Ks. Signed [Signature] Date 02/20/78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5