

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Mephereson Banks	Fraction NW 1/4 NE 1/4 SW 1/4	Section number 8	Township number T 21	Range number S R 5	(NW)
2. Distance and direction from nearest town or city: 1 1/2 mi N			3. Owner of well: Les Winget			
Street address of well location if in city: 1 1/2 E of Hutchinson, KS			R.R. or street: R.R. City, state, zip code: Inman, Ks. 67546			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 10 in. Well depth 60 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From To		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.25 lbs./ft. Dia. 6 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1255		
				10. Screen: Manufacturer's name _____ Type PUC Dia. 6" Slot/gauze .030 Length 20' Set between 40 ft. and 60 ft. Gravel pack? yes Size range of material F-12"		
Topsoil		0 4		11. Static water level: _____ mo./day/yr. 10 ft. below land surface Date 3-10-77		
Clay + silt		4 7		12. Pumping level below land surfaces: 55 ft. after 1 hrs. pumping 17 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 17 g.p.m.		
Sand Fine		7 20		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay gray		20 23		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 16 Inches above grade		
Sand Fine		23 27		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
Clay gray		27 42		16. Nearest source of possible contamination: ft. 75 Direction NW Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand - Fine		42 48		17. Pump: _____ Not installed Manufacturer's name Valley Model number S1208 HP 1/2 Volts 230 Length of drop pipe 50 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay gray		48 50				
Sand Fine		50 58				
Clay - gray imbedded with small shells		58 60				
loose rock + clay		60 62				
Shale red + green		62 64				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 137 Business name Hutchinson/Ks. License No. _____ Address Joe Miller 4-16-77 Signed _____ Date _____ Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023