## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County Fraction		Section	number	Township number	Range number	
1. Location of well:	McPherson	NW1/4 N E 1/4 NW1/4	3	٤	T 2/ s	R S	E,
2. Distance and direction from nearest town or city: 3 M; N, 4 E 3. Owner of well: Sam Lewis  R.R. or street: RR5							
Street address of well			Ve 17.	501			
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia.	. Completon date	-77
N N					Well depth 78 ft.		22.5
Sewer					7 Cable tool <b>*</b> Rotary Hollow rod Jetted		
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \					8. Use: Domestic F		
						Air conditioning St Dil field water C	tock Other
					X. Casing: Material PIS		
±					Threaded Welded RMP PVC		
1 Mile					Dia. 6 in. to 78 ft. de	pth Wall Thickness: ir	ı
5. Type and color of material				То	Dia in. to ft. de  10. Screen: Manufacturer's	<del></del>	
Rlack Too Sail				4			
Black Top Soil					Type PUC	Dia <b>6</b> Length <b>_3</b>	. •
Brown clay				24	Set between 48	_ft. and and	ft.
Sand + silt			24	35-	Gravel pack? Les Size r	ange of material	- /2
rocky Rubble			35	38	11. Static water level:		./day/yr.
				5-6	12. Pumping level below lar		
dark gray clay					23 ft. after 2	hrs. pumping 25	I
Fine sand+ silt				77	ft. after Estimated maximum yield	or sin	g.p.m.
red shale				80	13. Water sample submitted:	mo	./day/yr.
					Yes No  14. Well head completion:	Dule 8	NUTE
<u> </u>					Pitless adapter	Inches above	grade
					With: Neat cement Bentonite Concrete Depth: From 1 ft. to 1 ft.		
•							
					16. Nearest source of possib	Type 5	ewer
	· · · · · · · · · · · · · · · · · · ·				Well disinfected upon compl	etion? 🔼 Yes	No
					17. Pump:  Manufacturer's name	Not installed	·/   ~ [U
					Model number 51264	_ нР <u>// 3</u> _ vo	lts 230
					Length of drop pipe Type:	ft. capacity 🚣	∠g.p.m.
	0-1-1-1-1				Submersible  Jet	Turbin Recip	ocating
	(Use a second s	heet if needed)			Centrifugal	Other	
18. Elevation: 19. Remarks:					20. Water well contractor's This well was drilled under r		s report
High Nitrates - 143 ppm					is true to the best of my know		127 315
Topography: Hill					Miller Way	er Well Lie	ense No. 2
Slope					Address Hatchin	son Ks	-45-20 E
Upland Valley					Signed Authorized re	presentative Sate	Z   Z   Z   Z