


1 LOCATION OF WATER WELL: Fraction SW 1/4 NW 1/4 SW 1/4 Section Number 11 Township Number T 21 S Range Number R 6 EW
 County: Rice

Distance and direction from nearest town or city street address of well if located within city?
2 mi West 1/2 mi South of Plum & Sterling Rd

2 WATER WELL OWNER: Ray Smith
 RR#, St. Address, Box #: RR 2
 City, State, ZIP Code: Emman ks 67546
 Board of Agriculture, Division of Water Resources
 Application Number:



4 DEPTH OF COMPLETED WELL: 63 ft. ELEVATION:
 Depth(s) Groundwater Encountered 1. 1 ft. 2. 20 ft. 3. 7-24-91 ft.
 WELL'S STATIC WATER LEVEL 20 ft. below land surface measured on mo/day/yr
 Pump test data: Well water was 60 ft. after 2 hours pumping 15 gpm
 Est. Yield 15 gpm: Well water was 60 ft. after 2 hours pumping 15 gpm
 Bore Hole Diameter 9 in. to 63 ft., and 63 in. to 63 ft.
 WELL WATER TO BE USED AS:
 5 Public water supply 8 Air conditioning 11 Injection well
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
 Was a chemical/bacteriological sample submitted to Department? Yes.....No.....; If yes, mo/day/yr sample was submitted
 Water Well Disinfected? Yes No

5 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped
2 PVC 4 ABS 7 Fiberglass 9 Other (specify below) Welded
 Blank casing diameter 5 in. to 50 ft., Dia 14 in. to 50 ft., Dia 50 in. to 50 ft., Dia 50 in. to 50 ft.
 Casing height above land surface 14 in., weight 50 lbs./ft. Wall thickness or gauge No. SAR-20
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)
 12 None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 SCREEN-PERFORATED INTERVALS: From 30 ft. to 63 ft., From 30 ft. to 63 ft., From 30 ft. to 63 ft., From 30 ft. to 63 ft.
 GRAVEL PACK INTERVALS: From 40 ft. to 63 ft., From 40 ft. to 63 ft., From 40 ft. to 63 ft., From 40 ft. to 63 ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grout Intervals: From 0 ft. to 20 ft., From 0 ft. to 20 ft., From 0 ft. to 20 ft., From 0 ft. to 20 ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
 13 Insecticide storage
 Direction from well? N How many feet? 80

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>8</u>	<u>Sand</u>			
<u>8</u>	<u>14</u>	<u>Clay</u>			
<u>14</u>	<u>55</u>	<u>Sand & Clay</u>			
<u>55</u>	<u>63</u>	<u>Sand FINE</u>			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 9-24-91 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 440 This Water Well Record was completed on (mo/day/yr) 9-24-91 under the business name of Carl's Best Service by (signature) Ray Smith