

This is a manifold system

1 LOCATION OF WATER WELL

County: Rice

Distance and direction from nearest town or city? 3/4 miles Southwest of Sterling

2 WATER WELL OWNER: John Keeley

RR#, St. Address, Box #: P.O. Box 127

City, State, ZIP Code: Sterling, KS 67579

3 DEPTH OF COMPLETED WELL: 44 ft. Bore Hole Diameter: 24 in. to 44 in.

Well Water to be used as:

1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well

2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)

7 Lawn and garden only 10 Observation well

Well's static water level: 6 ft. below land surface measured on 5 month 13 day 1980 year

4 TYPE OF BLANK CASING USED:

1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile

2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below)

7 Fiberglass

Blank casing dia: 16 in. to 20 ft. Dia: 12 in. weight: 31.75 lbs./ft. Wall thickness or gauge No: 188

TYPE OF SCREEN OR PERFORATION MATERIAL:

1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement

2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify)

9 ABS 12 None used (open hole)

Screen or Perforation Openings Are:

1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)

2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes

7 Torch cut 10 Other (specify) Doerr Bridge Slot

5 GROUT MATERIAL:

1 Neat cement 2 Cement grout 3 Bentonite 4 Other

Grouted Intervals: From 0 ft. to 15 ft.

What is the nearest source of possible contamination:

1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well

2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well

3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) FIELD

Direction from well: n/a How many feet: n/a Water Well Disinfected? Yes No X

Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted: month day year Pump Installed? Yes X No

If Yes: Pump Manufacturer's name: Berkeley Pump Co. Model No. B4JRBM HP 25 Volts 460

Depth of Pump Intake (3 wells tied to this pump): ft. Pumps Capacity rated at 500 gal./min.

Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 5 month 13 day 1980 year

and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 185

This Water Well Record was completed on 9 month 12 day 1980 year under the business name of Clarke Well & Eq., Inc. by (signature)

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	2	Topsoil			streaks 28-30'
2	16	Fine-Med, sand & gravel w/streaks coarse gravel	34	38	Fine sand w/streaks sand & clay
16	20	Med-Coarse sand & gravel strk sandy yellow clay at 18'	38	44	Fine-Med. sand & gravel streak brown clay @ 43'
20	22	Fine-Med. sand & gravel			
22	27	Fine sand & gravel, strk fine sand @ 22'			
27	28	Fine-Med. sand & gravel			
28	34	Brown sardy clay w/gravel			

Depth(s) Groundwater Encountered 1... 6 ft. 2... ft. 3... ft. 4... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T

21

R

8

FWD

SEC.

29

3/4 W 1/4

1/4