WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

						Topeka, Kansas 60620	1	
1. Location of well:	County Fraction		Section number		Township number Range number			
. Locuitori or well:	Rice	NE 1/4 NW 1/4 X	XXX	32		T 21 S R 9	€₩	
4 3/4 miles Southwest of Alden, KS Street address of well location if in city: R.R. or st					Route 1 pte. zip code: Alden KS 67512			
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 9 in. Completion date Well depth 60 ft.	<u>8-30-</u> 78	
X						7 Cable tool X_ Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary		
E E E E E E E E E E E E E E E E E E E						8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water X Other—Fish		
SW SE						9. Casing: Materia Styren Reight: Above or below Threaded Welded X Surface 12 in. RMP PVC Weight 1.5 _lbs./ft.		
5. Type and color of material				From	То	Dia. 5 in. to 30 ft. depth Wall Thickness; inches or Dia. in. to ft. depth gage No. 200		
Top soil & gray clay				0	8	10. Screen: Manufacturer's name Jess &	Z TomeTh	
Sand & gravel				8	25	Slot/gauze1/8" Length30'		
Brown clay				25	29	Set between 30 ft. and 60 ft. ft. andft. Gravel pack? Yes Size range of material 3/8-200		
Sand & gravel				29	45	11. Static water level:		
Yellow clay				45	48	12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m.		
Sand & gravel				48	51	ft. after hrs. pumping g.p.m.		
Yellow clay				51	52	Estimated maximum yieldg.p.m. 13. Water sample submitted:mo./day/yr.		
Sand & gravel				52	60	Yes X No Date		
						Pitless adapter 12 Inches about 15. Well grouted? Yes	ove grade	
						With: Neat cement Bentonite Concrete Depth: From 0 ft. to 10 ft.		
						16. Nearest source of possible contamination: FIELD ft Direction Type		
						Well disinfected upon completion?XX Yes		
						17. Pump: X Not install Manufacturer's name	ed ~ ~	
						Model number		
						Type: Submersible Tur	bine L	
(Use a second sheet if needed)						Jet Rec Centrifugal Oth	iprocating	
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and	this report	
Topography:						is true to the best of my knowledge and belief. Clarke Well & Eq., Inc.	185	
Hill Slope							License No.	
Upland Valley						Signed Authorized representative	1-16-79	