


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Harvey	Township name Emma	Fraction SE 1/4 SW 1/4	Section number 13	Town number 22S	Range number 1-W		
Distance and direction from nearest town or city: 2 1/2 Mi. East 1 Mi. South of Hesston			3 Owner of well: Jerry Weever Address: Hesston, Kansas					
Locate with "X" in section below: N  W S E 1 Mile			Sketch map:			4 Well depth: 102 ft. Date of completion 4-25-75 Well diameter 9 in. To 20 7 in. To 102 Ft.		
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Yellow Clay		0	20	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
			Shale & Sandstone		20	27	7 Casing: Material Plastic Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. Class 160 Weight 160 lbs./ft. 5 in. 102 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth	
			Yellow Clay		27	38	8 Screen: Certain-teed Manufacturer Plastic Dia. 5 in. Slot/gauze 1/8 Length 15 Set between 85 ft. and 100 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4	
			Blue Shale		38	50	9 Static water level: 70 ft. below land surface Date 4-25-75	
			Red Rock		50	55	10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
			Blue Shale		55	70	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
			White Rock		70	80	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
			Blue Shale		80	95	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 4 ft. to 15 ft.	
			Water		95	97	14 Nearest source of possible contamination: ft. 2 Mi. Direction West Type Cattle Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Blue Shale		97	102	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(use a second sheet if needed)								
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhus Drilling 180 Business name License No. Address Topeka, Kansas Signed Paul Backhus Date 5-19-75 Authorized representative					