


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction S 1/2 NE 1/4	Section number 14	Township number T - 22 - S	Range number R - 1 - W
2. Distance and direction from nearest town or city: 2000 FEET NW		3. Owner of well: AMOS HILL R.R. or street: RR. City, state, zip code: HESTON KANSAS 67114				
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 8 in. Completion date 8-4-77 Well depth 40 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top Soil		0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Red CLAY		5	8	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
MED. COARSE BROWN SAND		8	16	Dia. 4 in. to 20 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
GREY & PINK CLAY		16	25	10. Screen: Manufacturer's name PEERLESS Type PVC Dia. 4 Slot/gauze 0.10 Length 20' Set between 8-18 ft. and 25-35 ft. ft. and <input type="checkbox"/> ft.		
MED. & FINE BROWN SAND		25	35	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"		
GREEN SHALE		35	40	11. Static water level: <input type="checkbox"/> mo./day/yr. 8 ft. below land surface Date 8-4-77		
				12. Pumping level below land surfaces: 15 ft. after 1 1/2 hrs. pumping 18-20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 18-20 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 300 Direction S-E Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON & RR. 138A Business name BOX 155 HINDSBOROUGH KS License No. <input type="checkbox"/> Address 2-1-77 Signed Larry E. Kodine Date <input type="checkbox"/> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5