

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: HARVEY		SE 1/4 NW 1/4 NW 1/4	15	T 22 S	R 1 EW
Distance and direction from nearest town or city?			Street address of well if located within city?		
			SAME		
2 WATER WELL OWNER: LOW WILLEMS					
RR#, St. Address, Box #: 302 PARK RD					
City, State, ZIP Code: HESSTON, KS 67062					
Board of Agriculture, Division of Water Resources Application Number:					
3 DEPTH OF COMPLETED WELL: 48 ft. Bore Hole Diameter: 11 in. to 40 ft., and ... in. to ... ft.					
Well Water to be used as:					
1 Domestic		3 Feedlot		5 Public water supply	
2 Irrigation		4 Industrial		6 Oil field water supply	
		7 Lawn and garden only		8 Air conditioning	
				9 Dewatering	
				10 Observation well	
				11 Injection well	
				12 Other (Specify below)	
Well's static water level: 16 ft. below land surface measured on ... month ... day ... year					
Pump Test Data: Well water was 45 ft. after 11/2 hours pumping 10 gpm					
Est. Yield 10 gpm: Well water was ... ft. after ... hours pumping ... gpm					
4 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		5 Wrought iron	
2 PVC		4 ABS		6 Asbestos-Cement	
				7 Fiberglass	
				8 Concrete tile	
				9 Other (specify below)	
				Casing Joints: Glued ... Clamped ...	
				Welded ...	
				Threaded ...	
Blank casing dia 5 in. to 48 in. Dia ... in. to ... ft. Dia ... in. to ... ft.					
Casing height above land surface 18 in., weight 2.32 lbs./ft. Wall thickness or gauge No 214					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel		5 Fiberglass	
2 Brass		4 Galvanized steel		6 Concrete tile	
				8 RMP (SR)	
				9 ABS	
				10 Asbestos-cement	
				11 Other (specify)	
				12 None used (open hole)	
Screen or Perforation Openings Are:					
1 Continuous slot		3 Mill slot		5 Gauzed wrapped	
2 Louvered shutter		4 Key punched		6 Wire wrapped 1020	
				7 Torch cut	
				8 Saw cut factory	
				11 None (open hole)	
Screen-Perforation Dia 5 in. to 35 ft. Dia ... in. to ... ft. Dia ... in. to ... ft.					
Screen-Perforated Intervals: From 25 ft. to 35 ft. From ... ft. to ... ft. From ... ft. to ... ft.					
Gravel Pack Intervals: From 10 ft. to 48 ft. From ... ft. to ... ft. From ... ft. to ... ft.					
5 GROUT MATERIAL:					
1 Neat cement		2 Cement grout		3 Bentonite	
4 Other					
Grouted Intervals: From 0 ft. to 10 ft. From ... ft. to ... ft. From ... ft. to ... ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Cess pool		7 Sewage lagoon	
2 Sewer lines		5 Seepage pit		8 Feed yard	
3 Lateral lines		6 Pit privy		9 Livestock pens	
				10 Fuel storage	
				11 Fertilizer storage	
				12 Insecticide storage	
				13 Watertight sewer lines	
				14 Abandoned water well	
				15 Oil well/Gas well	
				16 Other (specify below)	
Direction from well North How many feet 15 ? Water Well Disinfected? Yes No					
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample ...					
was submitted ... month ... day ... year: Pump Installed? Yes No					
If Yes: Pump Manufacturer's name Pumpco Model No. 41056 HP 1/3 Volts 230					
Depth of Pump Intake 46 ft. Pumps Capacity rated at 10 gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Oct month 2 day 1980 year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 175					
This Water Well Record was completed on 10 month 10 day 80 year under the business name of PAUL'S INC by (signature) Paul Bunchart					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0 5 LOAM / Fill Dirt			
		5 10 R2-BR CLAY			
		10 15 SANDY R2-BR CLAY			
		15 20 MED. BR SAND w/ CLAY Seams			
		20 25 SOFT BR-WHITE CLAY			
		25 28 WHITE CLAY w/ SAND Seams			
		28 35 MED to FINE SAND			
		35 40 GREEN to Red shale			
		40 45 Red to grey shale			
		45 48 Grey to dark shale			
ELEVATION: Depth(s) Groundwater Encountered 1. ... ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)					

OFFICE USE ONLY

T

R

EW

SEC

SE 1/4 NW 1/4 NW 1/4