

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:	County HARVEY	Fraction NE 1/4 NW 1/4 NW 1/4	Section number 15	Township number T 22 S	Range number R 1 E (W)																
2. Distance and direction from nearest town or city: Street address of well location if in city: Same			3. Owner of well: ERNEST HEIDE BRECHT R.R. or street: 112 MEADOW LANE City, state, zip code: HESTON, KANS 67062																		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> <div> <p>Sketch map:</p> </div> </div>			6. Bore hole dia. 12 in. Completion date 6/17/76 Well depth 48 ft.																		
5. Type and color of material			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																		
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;">From</th> <th style="width:20%;">To</th> </tr> </thead> <tbody> <tr> <td>Top loam</td> <td>0 3</td> </tr> <tr> <td>brown clay</td> <td>3 8</td> </tr> <tr> <td>alkali clay</td> <td>8 18</td> </tr> <tr> <td>brown clay</td> <td>18 25</td> </tr> <tr> <td>small to med sand</td> <td>25 34</td> </tr> <tr> <td>green-grey to blue shale</td> <td>34 38</td> </tr> <tr> <td>brown shale to dark</td> <td>38 48</td> </tr> </tbody> </table>			From	To	Top loam	0 3	brown clay	3 8	alkali clay	8 18	brown clay	18 25	small to med sand	25 34	green-grey to blue shale	34 38	brown shale to dark	38 48	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From	To																				
Top loam	0 3																				
brown clay	3 8																				
alkali clay	8 18																				
brown clay	18 25																				
small to med sand	25 34																				
green-grey to blue shale	34 38																				
brown shale to dark	38 48																				
(Use a second sheet if needed)			9. Casing: Material plastic Height: above 12" in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.23 lbs./ft. Dia. 6 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 255																		
10. Screen: Manufacturer's name Rebels-Tech-own slot Type PVC Dia. 6" Slot/gauze .064 Length 10' Set between 28 ft. and 38 ft. Gravel pack? yes Size range of material 1/8"-1/4"			11. Static water level: <input type="checkbox"/> mo./day/yr. 15 ft. below land surface Date 6/17/76																		
12. Pumping level below land surfaces: 38 ft. after 1 hrs. pumping 18 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 18 g.p.m.			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____																		
14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																		
16. Nearest source of possible contamination: house ft. 24' Direction South Type sewer Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name VALLEY Model number S-1809-FHP 1/2 Volts 230 Length of drop pipe 40 ft. capacity 18 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAULIS INC #175 Business name License No. Address HESTON, KANS Signed Paul Burlant Date 6/17/76 Authorized representative																		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5