


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County HARVEY	Township name EMMA	Fraction NE 1/4 / NE 1/4	Section number 16	Town number T-22-5	Range number R-1-W
Distance and direction from nearest town or city: Street address of well location if in city: 517 N WEAVER				3 Owner of well: Milford Reusser Address: 517 N. WEAVER		
Locate with "X" in section below: N  W S 1 Mile				Sketch map:		
2				4 Well depth: 30 ft. Date of completion 9/10/75 Well diameter 13 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
From To				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry ye <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Loam to clay				7 Casing: Material PVC Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 22 in. Diam. 6" Weight 3.22 lbs./ft. + 12 in. to 30 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
dark clay				8 Screen: own slot Manufacturer CERT-TEEL Type PVC Dia. 6" Slot/gauze .0468 Length Set between 15 ft. and 30 ft. Fittings: 1 1/2" x 1 1/4" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
light br. clay				9 Static water level: 12 1/2 ft. below land surface Date 9/10/75		
" " " with ALUMI				10 Pumping level below land surfaces: 17 1/2 ft. after _____ hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 35 g.p.m.		
SANDY clay				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
SAND Med size				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
blue green Shale				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 10 ft. to 0 ft.		
(use a second sheet if needed)				14 Nearest source of possible contamination: house sewer ft. _____ Direction North Type Line CI Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
16 Remarks: elevation				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC #175 Business name License No. Address Box 26 HEATON Signed Paul Beal Date 9/10/75 Authorized representative		