


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>HARVEY</b>	Township name <b>EDMONT</b>	Fraction <b>NW 1/4 - NE 1/4</b>	Section number <b>16</b>	Town number <b>T-22-S</b>	Range number <b>R-1-W</b>
Distance and direction from nearest town or city: <b>(N) HESSTON</b>			3 Owner of well: <b>Roy Smith</b>			
Street address of well location if in city: <b>106 W Vesper</b>			Address: <b>106 W VESPER - HESSTON</b>			
Locate with "X" in section below: 			Sketch map:			4 Well depth: <b>33</b> ft. Date of completion <b>6/2/25</b> Well diameter <b>6 1/2</b> in. <b>12 1/2</b> hole
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
					7 Casing: Material <b>PVC</b> Height: <b>above</b> below Threading <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12 1/2</b> in. Diam. <b>6 1/2</b> Weight <b>3.22</b> lbs./ft. <b>12</b> in. to <b>33</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					8 Screen: <b>own slot</b> Manufacturer <b>Leak-Tech</b> Type <b>PVC</b> Dia. <b>6 1/2</b> Slot/gauze <b>0.046</b> Length <b>10'</b> Set between <b>20</b> ft. and <b>30</b> ft. Fittings: <b>1/8 - 3/8"</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material	
					9 Static water level: <b>10 1/2</b> ft. below land surface Date <b>6/8/25</b>	
					10 Pumping level below land surfaces: <b>30</b> ft. after <b>1</b> hrs. pumping <b>15</b> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>15</b> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <b>12"</b> inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>15</b> ft. to <b>0</b> ft.	
					14 Nearest source of possible contamination: ft. <b>39</b> Direction <b>North</b> Type <b>city sewer - trap</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>PAUL'S INC</b> <b>#125</b> Business name License No. Address <b>Box 26 HESSTON</b> Signed <b>Paul Bunkert</b> Date <b>6/8/25</b> Authorized representative			