

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 18	Township number T 22 S	Range number R 1 E
2. Distance and direction from nearest town or city: 1 1/4 mi West OF HESSTON KS			3. Owner of well: HAROLD HERMSTINE R.R. or street: Box 1037 City, state, zip code: HESSTON KS		
4. Locate with "X" in section below:			Sketch map: HOUSE DUTCH AVE		
<p>150 ft X WELL</p> <p>LAGOON</p>			6. Bore hole dia. 10 in. Completion date 12-21 Well depth 55 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PITB Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.5 lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name J & L Type RMP Dia. 5 Slot/gauze .06 Length 20 Set between 35 ft. and 55 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 48		
			11. Static water level: 16 ft. below land surface Date 12-20-76 12. Pumping level below land surfaces: 45 ft. after 1 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8 g.p.m.		
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			16. Nearest source of possible contamination: ft. 150 Direction S Type LAGOON Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
17. Pump: Manufacturer's name PUMPCO Model number _____ HP 1/2 Volts 230 Length of drop pipe 45 ft. capacity 7 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D. R. Reed Service 211 Business name _____ License No. _____ Address 428 W 3rd Newton KS Signed [Signature] Date 2-1-77 Authorized representative		
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: (Use a second sheet if needed)		

22-10-18 NE NW NE
 Sec 18
 T 22 S R 1 E