



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Harvey		Fraction SE 1/4 NW 1/4 NE 1/4	Section number 20	Township number T 22 S	Range number R 1 E
2. Distance and direction from nearest town or city: 1 mile west of Hesston			3. Owner of well: Richard Vogt R.R. or street: Hesston, KS 67062 City, state, zip code:		
4. Locate with "X" in section below: 		Sketch map: 		6. Bore hole dia. 14 in. Completion date 6-26-79 <input checked="" type="checkbox"/> Well depth 35 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Silt - Loam		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown Clay		2	7	9. Casing: Material Plastic Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.58 lbs./ft. Dia. 6 in. to 38 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 280	
Grey Sandy Clay		7	15	10. Screen: Manufacturer's name Peerless Type PVC Dia. 6" Slot/gauze .030 Length 10 Set between 23 ft. and 33 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 1/4	
Grey clay w/ Sand Seams		15	25	11. Static water level: 21 ft. below land surface Date 6/20/79 mg./day/yr.	
Sand & Gravel		25	29 1/2	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. 35 ft. after 1 1/2 hrs. pumping 15 g.p.m. Estimated maximum yield 15 g.p.m.	
Green / Grey Shale		29 1/2	35	<input checked="" type="checkbox"/> Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 0 ft.	
				16. Nearest source of possible contamination: house ft. 300 Direction West Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC. #175 Business name License No. Address Box 24 Hesston Signed Paul Paulson Date 6/28 Authorized Representative	