USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	HARVEY	SE 1/4 SW 1/4 SW 1/4	22	T 22-S S	R R 1-W E/W

2. Distance and direction from nearest town or city: 1 MILE S.
Street address of well location if in city: 1/4 E FROM HESSTON

3. Owner of well: ALLEN SCHRAG
R.R. or street: RR #
City, state, zip code: HALSTEAD KANS 67056

4. Locate with "X" in section below:



Sketch map:



6. Bore hole dia. 8 in. Completion date 10-9-78
Well depth 58 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material ____ Height: Above or below
Threaded ____ Welded ____ Surface 12 in.
RMP X PVC ____ Weight ____ lbs./ft.
Dia. 5 in. to 58 ft. depth Wall Thickness: inches or
Dia. ____ in. to ____ ft. depth gage No. .200

5. Type and color of material	From	To
CLAY	0	6
FINE SAND	6	10
CLAY - BROWN	10	17
CLAY - GRAY	17	30
CLAY - DARK GRAY	30	45
CLAY + SAND - MEAIM TO COURSE	45	54
SHALE	54	58
(Use a second sheet if needed)		

10. Screen: Manufacturer's name SUNFLOWER PLAS. PIPE
Type .200 Dia. 5"
Slot/gauze 1/8 Length 20
Set between 38 ft. and 58 ft.
____ ft. and ____ ft.
Gravel pack? X Size range of material 1/4-1/2

11. Static water level: mo./day/yr.
24 ft. below land surface Date ____

12. Pumping level below land surfaces:
____ ft. after ____ hrs. pumping ____ g.p.m.
____ ft. after ____ hrs. pumping ____ g.p.m.
Estimated maximum yield 8 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date ____

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? YES
With: __ Neat cement __ Bentonite X Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 60' Direction S Type BARN YARD
Well disinfected upon completion? X Yes __ No

17. Pump: __ Not installed
Manufacturer's name GOULDS
Model number 10E50412 HP 1/2 Volts 230
Length of drop pipe 56 ft. capacity 10 g.p.m.
Type:
X Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation:

Topography:
__ Hill
X Slope
__ Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
MARTIN SUPPLY 362
Business name License No.
Address 500 W 22ND NEWTON
Signed Butch Schmidt Date 10-2-78
Authorized representative

T 22 - 1 W E
R
Sec 22 SE SW SW
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5