


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction N 1/2 NW 1/4 NE 1/4	Section number 31	Township number T 22 S	Range number R 1W E 1
2. Distance and direction from nearest town or city:		5 miles No. of Hwy		Owner of well: Don Stutzman		
Street address of well location if in city:		50 and 2 1/2 miles W. of Ridge Rd. on		R.R. or street: R.R. #1 City, state, zip code: Halstead, Kansas		
4. Locate with "X" in section below:		Sketch map: the Southside of the road. Hesston, Kansas			6. Bore hole dia. 11 in. Completion date 4-28-78 Well depth 105 ft.	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Topsoil		0			9. Casing: Material styrene Height: Above or below 44 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 105 ft. depth Wall Thickness: inches or .200 Dia. 5 in. to 105 ft. depth Gauge No. 200	
Clay		3			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot .06 Length 15' Set between 90 ft. and 105 ft. Set between 90 ft. and 105 ft. Gravel pack? yes Size range of material 1/4-1/8"	
Fine Sand		21			11. Static water level: 20 ft. below land surface Date 4-28-78 mo./day/yr. 4-28-78	
Gray Clay		30			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
Fine Sand		90			13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____	
Gray Shale		93			14. Well head completion: capped ____ Pitless adapter 12 Inches above grade	
					15. Well grouted? yes 1-2 Fine Sand Mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.	
					16. Nearest source of possible contamination: ft. 150 Direction S.E. Type Lagoon Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
18. Elevation:		19. Remarks: Flat Ground			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Wichita, Kansas Signed M. Arnold Date 6-24-78 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5