

TEST PUMPING RESULTS & PUMP INSTALLATION

Customer Titus Address _____ Date 11-5-74
Well Site _____ Sec 4 T 22 R 10W County Beno

TEST PUMPING RESULTS

New Well ☒ Workover _____ Well Depth 42 Ft.

W.L. at start 8, at finish _____ Pumped _____ hrs. before test

thru 4 in. discharge. Ran 40 Test Pump, _____ Tailpipe.

Gravel Settled _____ ft. Csg. cut off at 2 ft. 7 G.L.

Did well pump sand _____ mud _____ for _____ Took water sample yes

RPM GPM DD TIME

REMARKS

~~1000 650 32~~
~~900 600 30~~
~~800 550 28~~

1000 650 32
900 600 30
800 550 28

Left pumping
500 g.p.m.

Best Available Copy

PUMP INSTALLATION

New _____ Used _____ Well Depth _____ P. Setting _____

Make _____ W.L. _____ O.L. _____, Drive Shaft Size _____

Column: _____ in., _____ jts., Total ft. _____ Type _____

Bowls: Lng. _____, Dia. _____ IMP. _____, Stages _____

Head Ser. No. _____

Other _____

POWER

Gearhead: Make _____, HP _____ Ratio _____ Ser. No. _____

Frame _____ Type _____ Head Shaft _____

Electric Motor: Make _____ HP _____ Volts _____ Ph _____ Cyc _____

Amps _____ M. Amps _____ Model _____ RPM _____

SUBMERSIBLE PUMP

Make _____ HP _____ Volts _____ RPM _____ Ph _____

Model _____ Cyc _____ Amps _____ M. Amps _____

Operator Norman Hillman