

LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number		
County: STAFFORD		SE 1/4 SW 1/4 SW 1/4	29	T 22 S	R 11 E		
Distance and direction from nearest town or city? 5 1/8 E OF HUDSON, KS			Street address of well if located within city?				
WATER WELL OWNER: Brandt Drilling Company							
R#, St. Address, Box # : Suite 1104 Douglas Bldg.			Board of Agriculture, Division of Water Resources				
City, State, ZIP Code : Wichita, Kansas 67202			Application Number:				
DEPTH OF COMPLETED WELL: 95 ft. Bore Hole Diameter: 10 in. to ... ft., and ... in. to ... ft.							
Well Water to be used as:							
1 Domestic		3 Feedlot	5 Public water supply	8 Air conditioning	11 Injection well		
2 Irrigation		4 Industrial	6 Oil field water supply	9 Dewatering	12 Other (Specify below)		
7 Lawn and garden only		10 Observation well					
Well's static water level: 18 ft. below land surface measured on Sept month 26 day 80 year							
Pump Test Data							
St. Yield 70 gpm		Well water was ... ft. after ... hours pumping ... gpm	Well water was ... ft. after ... hours pumping ... gpm				
TYPE OF BLANK CASING USED:							
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	Casing Joints: Glued ☒ Clamped		
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded		
3 Fiberglass			7 Fiberglass		Threaded		
Blank casing dia 5 in. to 75 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.							
Casing height above land surface: 12 in., weight ... lbs./ft. Wall thickness or gauge No. 214							
TYPE OF SCREEN OR PERFORATION MATERIAL:							
1 Steel		3 Stainless steel	5 Fiberglass	7 PVC	10 Asbestos-cement		
2 Brass		4 Galvanized steel	6 Concrete tile	8 RMP (SR)	11 Other (specify)		
9 ABS		12 None used (open hole)					
Screen or Perforation Openings Are:							
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)		
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes			
7 Torch cut		10 Other (specify)					
Screen-Perforation Dia 5 in. to ... ft., Dia ... in. to ... ft., Dia ... in. to ... ft.							
Screen-Perforated Intervals:							
From 75 ft. to 95 ft.		From ... ft. to ... ft.					
Travel Pack Intervals:							
From 10 ft. to 95 ft.		From ... ft. to ... ft.					
GROUT MATERIAL:							
0 Neat cement		2 Cement grout	3 Bentonite	4 Other			
Grouted Intervals: From 0 ft. to 10 ft., From ... ft. to ... ft., From ... ft. to ... ft.							
What is the nearest source of possible contamination:							
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well		
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well		
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)		
13 Watertight sewer lines		NONE					
Direction from well ... How many feet ... ? Water Well Disinfected? Yes ☒ No							
Has a chemical/bacteriological sample submitted to Department? Yes ... No ☒ If yes, date sample ...							
As submitted ... month ... day ... year: Pump Installed? Yes ☒ No ☒							
Yes: Pump Manufacturer's name ... Model No. ... HP ... Volts ...							
Depth of Pump Intake ... ft. Pumps Capacity rated at ... gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was ☒ constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Sept month 26 day 80 year							
And this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 325							
This Water Well Record was completed on June month 24 day 81 year under the business name of Central Well & Pump Inc. Pratt, Kansas by (signature) Johnonich							
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		LITHOLOGIC LOG		LITHOLOGIC LOG			
		FROM 0	TO 2	Sandy silt	FROM 95	TO 105	Sand, med to coarse and coarse gravel
		2	10	Sand, fine			
		10	25	Clay, brown			
		25	35	Clay, white			
		35	45	Clay, brown with fine sand streaks			
		45	65	Sand, fine with white clay streaks			
		65	80	Sand, fine to med			
		80	95	Sand, fine to med and med gravel			
ELEVATION:							
Depth(s) Groundwater Encountered 1. 35 ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)							

OFFICE USE ONLY

T

82

R

11

E/D

SEC.

29

81

29

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4