WATER WELL RECORD Form WWC-5 KSA 82a-1212

| LOCATION OF WATER WELL | Fraction | Section Number | Township Number | Range Number |
|---|---|---|---|---|
| ounty: Stafford | csl/2 sl/2 ¼ ¼ nw ¼ | 9 | T 22 S | R 12w E/W |

istance and direction from nearest town or city? 3n 3/4e Hudson, Ks.

Street address of well if located within city?

WATER WELL OWNER: Woodman-Ianitti Drlg Co
R#, St. Address, Box # : 1008 Douglas Bldg
ity, State, ZIP Code : Wichita, Ks. 67202

Board of Agriculture, Division of Water Resources
Application Number: unknown

DEPTH OF COMPLETED WELL 120 ft. Bore Hole Diameter 8 in. to 120 ft., and in. to ft.

/ell Water to be used as: 1 Domestic 2 Irrigation 3 Feedlot 4 Industrial 5 Public water supply 6 Oil field water supply 7 Lawn and garden only 8 Air conditioning 9 Dewatering 10 Observation well 11 Injection well 12 Other (Specify below)

/ell's static water level 20 ft. below land surface measured on 6 month 5 day 80 year

ump Test Data : Well water was ft. after hours pumping gpm
st. Yield 75 gpm: Well water was ft. after hours pumping gpm

TYPE OF BLANK CASING USED: 1 Steel 2 PVC 3 RMP (SR) 4 ABS 5 Wrought iron 6 Asbestos-Cement 7 Fiberglass 8 Concrete tile 9 Other (specify below)

Casing Joints: Glued Clamped Welded Threaded

lank casing dia 5 in. to 100 ft., Dia in. to ft., Dia in. to ft.

asing height above land surface 12 in., weight 2.8 lbs./ft. Wall thickness or gauge No. sch 40

YPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 2 Brass 3 Stainless steel 4 Galvanized steel 5 Fiberglass 6 Concrete tile 7 PVC 8 RMP (SR) 9 ABS 10 Asbestos-cement 11 Other (specify) 12 None used (open hole)

creen or Perforation Openings Are: 1 Continuous slot 2 Louvered shutter 3 Mill slot 4 Key punched 5 Gauzed wrapped 6 Wire wrapped 7 Torch cut 8 Saw cut 9 Drilled holes 10 Other (specify) 11 None (open hole)

creen-Perforation Dia 5 in. to ft., Dia in. to ft., Dia in to ft.

creen-Perforated Intervals: From 100 ft. to 120 ft., From ft. to ft.
From ft. to ft., From ft. to ft.

ravel Pack Intervals: From 10 ft. to 120 ft., From ft. to ft.
From ft. to ft., From ft. to ft.

GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other

routed Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.

/hat is the nearest source of possible contamination:
1 Septic tank 2 Sewer lines 3 Lateral lines 4 Cess pool 5 Seepage pit 6 Pit privy 7 Sewage lagoon 8 Feed yard 9 Livestock pens 10 Fuel storage 11 Fertilizer storage 12 Insecticide storage 13 Watertight sewer lines 14 Abandoned water well 15 Oil well/Gas well 16 Other (specify below)

irection from well se How many feet 70 ? Water Well Disinfected? Yes No

/as a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample as submitted month day year: Pump Installed? Yes No

Yes: Pump Manufacturer's name Model No. HP Volts

epth of Pump Intake ft. Pumps Capacity rated at gal./min.

ype of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was ompleted on 6 month 5 day 80 year. nd this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186 his Water Well Record was completed on 6 month 16 day 80 year under the business ame of Kellys Waterwell Serv. by (signature) Kelly Price

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:




| FROM | TO | LITHOLOGIC LOG | FROM | TO | LITHOLOGIC LOG |
|---|---|---|---|---|---|
| 0 | 98 | Top Soil-Clay | | | |
| 98 | 120 | Sand-Gravel | | | |

ELEVATION: unknown

epth(s) Groundwater Encountered 1 98 ft. 2 ft. 3 ft. 4 ft. (Use a second sheet if needed)

NSTRUCTIONS: Use typewriter or ball point pen, *please press firmly* and *PRINT* clearly. Please fill in blanks, underline or circle the correct answers. Send top three opies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and etain one for your records.

OFFICE USE ONLY T 22 R 12 E/W SEC. 9 CS½ ¼ NW ¼ ¼